

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. LAB/MARCH/32

Dated: 12/03/2026


It is certified that an inspection team headed by Raman Kumar Jha Lab. Asst. (Name of Officers with designation) from PHED Madhubani

inspected the MADONA ENGLISH SCHOOL, BANKATTA, BENIPATTI, MADHUBANI (BIHAR) PIN 847223. (Name & Address of the school) on 10-03-2026 (date of inspection) and on the basis of Water Test

Report (Attached) bearing no LAB/MARCH/32 dated 12/03/2026 of Madhubani (PHED Lab)

certified that the MADONA ENGLISH SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 11.09.26

Signature with Seal: 
Name : Ashraf Najmi
Designation : Chemist
Name & Address of the Office / Department :

CHEMIST
P.H.E.D. Madhubani

To
MADONA ENGLISH SCHOOL,
BENIPATTI, BANKATTA,
MADHUBANI (BIHAR) PIN 847223.
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

**DISTRICT LEVEL WATER TESTING LABORATORY
P.H.DIVISION, MADHUBANI**

Sample Collected & Submitted by Raman Kumar Jha.
 Sampling Date:- 10/03/2026
 Testing Date:- 12/03/2026
 Months:- March, 2026

SI No.	Block	Panchayat	Village	Source of Water	Name of Location/Nearest Person	PH.	Tub.	T.H	T.A	Ca	Mg	Cl	Fe	F	SO4	NO3	TDS	EC	AS	Remarks
1	Benipatti	Bankatta	Bankatta	Boring	MADONA ENGLISH SCHOOL	7.6	2	125	216	26	8.7	20	0.18	0.16	00	0.3	184	272	NT	
Min-Max-Permissible Limit																				
6.5 - 8.5 1.0-05 200 - 600 200 - 600 75 - 200 30 - 100 250 - 1000 1.0 0.1 - 1.5 200 - 400 45 500 - 2000 0.01 - NR																				

*NT - Not Tested

*BDL- Below Detection Limit

Tish report is valid for six months from the testing.


 12/03/2026
 Lab. Assistant.
 District Laboratory, Madhubani


 Chemist
 District Laboratory, Madhubani